

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

## Monitoring Requirements Not Met for Lead and Copper

(Public Water System Name)

Our water system violated several drinking water regulations over the compliance period shown below. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are indicators of whether or not your drinking water meets health standards. During 6/1/2014 to 9/30/2014, we did not monitor for Lead and Copper,

(compliance period)

(contaminant(s))

and therefore cannot be sure of the quality of your drinking water during that time.

### What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the compliance period, how often we are supposed to sample and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were taken
Lead	5 per 3 years	0	By 9/30/2014	10/12/2014
Copper	5 per 3 years	0	By 9/30/2014	10/12/2014

### What happened? What is being done?

(describe corrective action.)

*We tested 12 days late for compliance. The results were below the maximum contaminate limits for lead and copper, but not sampled in a timely manner. We will be testing every year for 3 years to regain compliance with the Lead Copper Rule.*

For more information, please contact Clearwater Operations at 307-690-5512

(name of contact)

(phone number)

or PO Box 53, Teton Village, WY 83025. Please share this information

(mailing address)

with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hands or mail.

This notice is being sent to you by Skyline Ranch ISD. Public Water System ID#: 5600217

(system)

Date distributed: 9/29/2015

Skyline Lead Copper Sample / Testing

PWS#: WY5600217

Name: Skyline Ranch I&S District

EPA MCL/QCL	Copper	Lead	units
	1.3	0.0015	mg/L

Sample Date: 10/12/2014

Results of Testing

Sample Point / Location	Copper	Lead	units
3250 Mallard	0.04	ND	mg/L
3325 Killdeer	0.017	ND	mg/L
3225 Mallard	0.09	ND	mg/L
400 NW Ridge	0.03	ND	mg/L
400 Meadowlark	0.03	0.001	mg/L

Sample Date: 9/9/2015

Results of Testing

Sample Point / Location	Copper	Lead	units
3080 Mallard	0.07	ND	mg/L
3075 Mallard	0.05	0.001	mg/L
3170 Teal	0.4	ND	mg/L
225 NW Ridge	0.35	0.001	mg/L
400 Meadowlark	0.09	0.002	mg/L